

## APPENDIX 2J

### CONSTRUCTION ITEMS

Selection of Construction Items must be in consultation with the Authority and approved for use by the Authority through Appendix 2C [User Consultation and Review Process]

Construction Item Name	Description	Additional Information	DBF	CM
Air Gun, Wall Mounted	For medical device reprocessing; retractable pressurized tubing with regulator	Medical Device Reprocessing Decontamination and Facilities Maintenance & Operations	YES	NO
Air Gun, Ceiling Mounted	Workshop air gun	Facilities Maintenance & Operations	YES	NO
All types of dispensers (toilet paper/paper towel/soap/lotion/hand sanitizer/gloves/scrub sponges)	Refer to guidance documents from FHA Infection Prevention and Control. Consult Authority In-Hospital Replenishment for hospital and infection control approved dispensers.	Throughout Facility	YES	YES
Booth, Paint, Backdraft 2 ft x 4 ft	M-tek Open Face Spray Booth MT-OF 1098 or MT-OF 868		YES	NO
Cabinet, Storage, Flammable	4' x 4' flammable storage cabinet U-Line H-1563M 43"W x 18" D x 44" H colour Yellow RT	Each cabinet must have dedicated vent to outside	YES	YES
Cart/Truck, Pallet Jack - Electric	Push-button lift controls and forward/reverse thumb wheels, ergonomic handle, reverse safety switch, built-in and maintenance-free charger, 6 hours service per charge.	e.g. Model H-4710 ULINE.ca	YES	YES
Counter, S/S (for staining) with Backdraft, Fume Extraction	MOPEC or MorTech		NO	YES
Fume Hood, Industrial Exhaust	Filtered fume hood that require ducting for external exhaust via welded stainless steel ducting; must be able to filter acids, bases and solvents.	Facilities Maintenance & Operation Workshops; e.g. Labconco Protector Echo or Protector XL	YES	NO
Gun, Water Sprayer	Stainless steel spray gun, resistant to cold demineralized water, sterilisable (e.g. ProSys)		YES	NO
Hoist, Chain, Electric, 1000lb	Handheld control with 6' cord; 15' power cord with 3-prong plug; NEMA 4 rated; 115V; corrosion resistant zinc-plated steel chain with fabric chain bag; CSA approved.	e.g. Model H-8627 ULINE.ca	YES	NO

Construction Item Name	Description	Additional Information	DBF	CM
Holder, Signage	Plexiglas or other durable material, wall mounted, interactive patient care signage, internal communication or wayfinding signage; inside and/or outside rooms as required (e.g. patient rooms).	Customizable design with option for icons (e.g. LH Companies Patient Care Signage); throughout Facility	YES	YES
Kitchenware, Hood	Functional kitchen electric range and stove	Used for rehabilitation and re-training of patients on the use of stoves and oven during Occupational Therapy sessions	YES	NO
Laboratory Hood, Chemical Fume	Filtered fume hood that require ducting for external exhaust via welded stainless steel ducting; must be able to filter acids, bases and solvents.	e.g. Labconco Protector Echo or Protector XL	YES	NO
Lift, Scissor, Floor	210 degrees steering arc for easy maneuvering; 3000 lb capacity; automatically slows lowering speed to prevent damage with heavy loads.	e.g. Model H-5442 ULINE.ca	YES	NO
Mirror, Standing	Wall mounted, 24"W x 60"H Tempered glass metal framed mirror.	Gift Shop	YES	NO
Morgue Body Transfer System, Standard and Bariatric	Specifications for standard system is included in Schedule 3, bariatric version for the same system is required		YES	NO
Notice Board, Lockable, Wall mounted	We will also need a lockable wall mounted notice board, approx. 3 ft x 5 ft, installed right by the entrance of FMO Office (inside or outside) for posting safety bulletins.	Facilities Maintenance & Operations	YES	NO
Pole, patient support (installed)	Safety and security poles, grab bars, assist and stability rails. Must be Stainless steel with easily cleanable surfaces - approved by infection control.	Throughout Facility (e.g. bathrooms, bedrooms, rehabilitation rooms etc.)	YES	YES
Rack, Bar, Labouring	Wall mounted rack to store birthing bars		YES	NO
Rack, Body Tray, Standard and Bariatric	Specifications for standard system is included in Schedule 3, add the bariatric version of the same system		YES	NO
Rack, Hanging	Wall mounted racks to hang folded 2WW/canes/crutches		YES	YES
Rack, Mop/Broom	Wall mounted racks to hand mops/brooms.	Housekeeping closets, Housekeeping and Waste Management Component	YES	YES
Retail Display (slat boards, hooks, display cabinet)	Display cabinet; tempered glass; stainless steel or other cleanable material approved by infection control.	Retail Food, Gift Shop Components	YES	NO

<b>Construction Item Name</b>	<b>Description</b>	<b>Additional Information</b>	<b>DBF</b>	<b>CM</b>
Scale, Platform, On Floor	All weather low profile floor scale; 4'x4'x4"; 10,000 lbs capacity; recessed flush/level with the adjacent floor, not with a ramp.	Facilities Maintenance & Operations; e.g. H-7936 and H-758 (ramp) ULINE.ca	YES	NO
Storage, Secured Cage	Custom sized wired fencing enclosures supplied and installed by Riteway Fencing or Ace Link Fence Ltd. RT	Facilities Maintenance & Operations; In-Hospital Replenishment; Loading Dock Area	YES	YES
Storage, Vertical Bed	Hospital bedlift bed storage system; stacked securely in a vertical arrangement; up to 12 beds	e.g. Vidir Bedlift; Southwest Solutions Group Vertical BedLift Revit BIM models;	YES	NO
Table, Plans for Shop Drawings	Workshop plan reading tables sized to open full sized 36" x 48" hard copy plans. Table needs to be 48" deep x 100" wide.	Facilities Maintenance & Operations Workshops	YES	NO
Table, Folding, Wall-mounted	Industrial weighted laundry folding tables attached to wall.	Mental Health Component	YES	NO
Tub, Demonstration	Birthing tub with 3-sided panels that can be lowered/removed to allow for physician/midwife, partner and nurse access to mother at the same time; not plumbed, for demonstration purposes only.	Maternal-Child Labour and Delivery Room	YES	NO
Tub, Labouring	Functional (plumbed) birthing tub with 3-sided panels that can be lowered/removed to allow for physician/midwife, partner and nurse access to mother at the same time; These are fully plumbed with anti scald water temperature faucets. Labour tubs as described in the SoR: 7.4.4.1(14) Bath tubs in Patient Room-LDRP washrooms (Ensuite/Tub) will be accessed from 3 sides. Minimum internal tub dimensions will be 1320 mm long by 700 mm wide and 1016 mm deep. Tubs will be equipped with a step through door and a 3" drain for fast draining. Telephone shower from adjacent shower area will be used for washing tub occupant. Provide shower hose long enough to provide this function. 7.4.4.1(15) Bath tubs will be designed so the contents can be drained without reaching into the tub. This will be provided by mechanical or other means.	Maternal-Child Labour and Delivery Rooms	YES	NO
Tub, Patient	Bathtub	Patient washrooms throughout the Facility	YES	NO